

阅读申明

- 1.本站收集的数据手册和产品资料都来自互联网，版权归原作者所有。如读者和版权方有任何异议请及时告之，我们将妥善解决。
- 2.本站提供的中文数据手册是英文数据手册的中文翻译，其目的是协助用户阅读，该译文无法自动跟随原稿更新，同时也可能存在翻译上的不当。建议读者以英文原稿为参考以便获得更精准的信息。
- 3.本站提供的产品资料，来自厂商的技术支持或者使用者的心得体会等，其内容可能存在描述上的差异，建议读者做出适当判断。
- 4.如需与我们联系，请发邮件到marketing@iczoom.com，主题请标有“数据手册”字样。

Read Statement

1. The datasheets and other product information on the site are all from network reference or other public materials, and the copyright belongs to the original author and original published source. If readers and copyright owners have any objections, please contact us and we will deal with it in a timely manner.
2. The Chinese datasheets provided on the website is a Chinese translation of the English datasheets. Its purpose is for reader's learning exchange only and do not involve commercial purposes. The translation cannot be automatically updated with the original manuscript, and there may also be improper translations. Readers are advised to use the English manuscript as a reference for more accurate information.
3. All product information provided on the website refer to solutions from manufacturers' technical support or users the contents may have differences in description, and readers are advised to take the original article as the standard.
4. If you have any questions, please contact us at marketing@iczoom.com and mark the subject with "Datasheets" .

BT series
TIMER BTTT-S
Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 16

D-32758 Detmold

Germany

Fon: +49 5231 14-0

Fax: +49 5231 14-292083

www.weidmueller.com



BTT installation timing relay as universal clock generator. After connecting the voltage supply, two independently adjustable times (off and operating conditions) are counted down.

The timing relay is built into an Insta enclosure just 17.5 mm wide. The relay contact is designed as a changeover contact with 250 V/5 A switching capacity.

General ordering data

Order No.	8647740000
Type	TIMER BTTT-S
Version	BT series, Timing relay, No. of contacts: 1, CO contact, AgNi 90/10, Rated control voltage: 24...230 V AC, 24...48 V DC, Continuous current: 5 A, Screw connection
GTIN (EAN)	4032248308941
Qty.	10 pc(s).

**BT series
TIMER BTTT-S**

Weidmüller Interface GmbH & Co. KG
 Klingenbergstraße 16
 D-32758 Detmold
 Germany
 Fon: +49 5231 14-0
 Fax: +49 5231 14-292083
 www.weidmueller.com

Technical data**Ratings**

Conductor connection system	Screw connection	Humidity	35...85 % rel. humidity, no condensation
UL 94 flammability rating	V-2		

Dimensions and weights

Width	17.5 mm	Height	80 mm
Depth	73 mm	Net weight	79.8 g

Temperatures

Operating temperature	-10 °C...+55 °C	Storage temperature	-25 °C...+65 °C
-----------------------	-----------------	---------------------	-----------------

Input

Rated control voltage	24...230 V AC, 24...48 V DC	Power rating	≤ 0.4 VA, 1.6 W
Time ranges	0.10 s - 120 h	Repeat accuracy	± 1 %

Output

Max. switching voltage, AC	250 V	Continuous current	5 A
----------------------------	-------	--------------------	-----

Contact specifications

No. of contacts	1	Contact design	CO contact
Contact material	AgNi 90/10	Mechanical service life	10 ⁷ switching cycles (no load, 1800/h)
Electrical service life, DC coil	10 ⁵ switching cycles (5A at 250 Vac, ohm load at 1800/h)	Contact resistance	100 MΩ min., at 500 V DC

Insulation coordination

Protection degree	IP 30 // terminals IP 20
-------------------	--------------------------

Other technical data

Version	Timing relay
---------	--------------

Further details of approvals / standards

Certificate No. (UR)	E223474OMR	Standards	UL508
----------------------	------------	-----------	-------

Rated data UL

Certificate No. (UR)	E223474OMR
----------------------	------------

Classifications

ETIM 2.0	EC001439	ETIM 3.0	EC001439
UNSPSC	30-21-19-17	eClass 4.1	27-14-23-10
eClass 5.1	27-14-23-10	eClass 6.0	27-14-23-10
eClass 7.0	27-14-23-10		

Data sheet...

**BT series
TIMER BTTT-S**

Weidmüller Interface GmbH & Co. KG
Klingenbergstraße 16
D-32758 Detmold
Germany
Fon: +49 5231 14-0
Fax: +49 5231 14-292083
www.weidmueller.com

Technical data

Approvals

Approvals



Downloads

Declaration of Conformity [K258_08_03.pdf](#)