

阅读申明

- 1.本站收集的数据手册和产品资料都来自互联网，版权归原作者所有。如读者和版权方有任何异议请及时告之，我们将妥善解决。
- 2.本站提供的中文数据手册是英文数据手册的中文翻译，其目的是协助用户阅读，该译文无法自动跟随原稿更新，同时也可能存在翻译上的不当。建议读者以英文原稿为参考以便获得更精准的信息。
- 3.本站提供的产品资料，来自厂商的技术支持或者使用者的心得体会等，其内容可能存在描述上的差异，建议读者做出适当判断。
- 4.如需与我们联系，请发邮件到marketing@iczoom.com，主题请标有“数据手册”字样。

Read Statement

1. The datasheets and other product information on the site are all from network reference or other public materials, and the copyright belongs to the original author and original published source. If readers and copyright owners have any objections, please contact us and we will deal with it in a timely manner.
2. The Chinese datasheets provided on the website is a Chinese translation of the English datasheets. Its purpose is for reader's learning exchange only and do not involve commercial purposes. The translation cannot be automatically updated with the original manuscript, and there may also be improper translations. Readers are advised to use the English manuscript as a reference for more accurate information.
3. All product information provided on the website refer to solutions from manufacturers' technical support or users the contents may have differences in description, and readers are advised to take the original article as the standard.
4. If you have any questions, please contact us at marketing@iczoom.com and mark the subject with "Datasheets" .

DPADCV 0-10V

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 16

D-32758 Detmold

Germany

Fon: +49 5231 14-0

Fax: +49 5231 14-292083

www.weidmueller.com



Modules in the DPA SERIES are used for monitoring limit values. They can be configured for a wide variety of industrial signals and feature two relay contacts for the alarm function on the output side.

A potentiometer on the front side is used to custom adjust the setpoints and deadbands.

The deadband reduces chatter from the alarm relay during switching operations.

The reset point of the relay contact is individually adjusted, in this case away from the hysteresis (setpoint).

In order to generate an alarm in the event of a power outage, you should select the "energised" operational status for one or both of the output relays.

A high/low-trip switching behaviour can also be set independently for each channel.

The following analogue input signals can be processed with the current DPA SERIES: temperature (thermocouple and PT100 temperature sensors), AC/DC currents and voltages, measuring wire and potentiometer positions, resistances, differential currents and differential resistances.

The monitoring components are enclosed in a rugged rail-mountable metal housing and feature complete isolation at 2 kV.

General ordering data

Type	DPADCV 0-10V
Order No.	7940011718
Version	Signal converter/disconnector, 0...10 V or 1...5 V
GTIN (EAN)	4032248564354
Qty.	1 pc(s).

DPADCV 0-10V

Weidmüller Interface GmbH & Co. KG
 Klingenbergstraße 16
 D-32758 Detmold
 Germany
 Fon: +49 5231 14-0
 Fax: +49 5231 14-292083
 www.weidmueller.com

Technical data
Dimensions and weights

Width	46 mm	Height	97 mm
Depth	120 mm	Weight	424 g
Net weight	424 g		

Temperatures

Humidity	0...90 % (no condensation)	Operating temperature	0 °C...+60 °C
Storage temperature	-25 °C...+70 °C		

Input

Supply voltage	24 V DC \pm 10 %	Type	DC voltage [$>$ 500 mV]
Input resistance	1 M Ω (0...10 V) or 500 k Ω (1...5 V)	Input signal	0...10 V or 1...5 V

Settings

Fine adjustment	Potentiometer, 20 turns	Hysteresis	1...25 % of max. input value
Switching thresholds	0...100 % of max. input value		

General data

Input/Output	Voltage input	Long-term drift	0.1 % / 10.000 h
Mounting rail	TS 35, TS 32	Power consumption	3 W @ 24 V DC
Repeat accuracy	\pm 0.05 % of signal range	Step response time	typ. 5 ms
Supply voltage	24 V DC \pm 10 %	Temperature coefficient	$<$ 0.04 % / °C
Type of connection	Screw connection		

Insulation coordination

EMC standards	DIN EN 61326	Impulse withstand voltage	4 kV (1.2/50 μ s)
Insulation voltage	2 kV input / output / power supply	Standards	DIN EN 50178

Classifications

ETIM 3.0	EC001774	UNSPSC	30-21-18-01
eClass 6.2	27-21-09-90	eClass 7.1	27-21-09-90

Product information

Descriptive text technical data	PE connection direct on enclosure
---------------------------------	-----------------------------------

Approvals

Approvals



ROHS	Conform
------	---------

Data sheet

DPADCV 0-10V

Weidmüller Interface GmbH & Co. KG
Klingenbergstraße 16
D-32758 Detmold
Germany
Fon: +49 5231 14-0
Fax: +49 5231 14-292083
www.weidmueller.com

Technical data

Downloads

Declaration of Conformity [K_460_07_11.pdf](#)

Data sheet

DPADCV 0-10V

Weidmüller Interface GmbH & Co. KG
 Klingenbergstraße 16
 D-32758 Detmold
 Germany
 Fon: +49 5231 14-0
 Fax: +49 5231 14-292083
 www.weidmueller.com

Drawings

Electric symbol

